CONFORMITY TO

- ASCE 25-16 technical standard
- PED (essential requirements)

SV VALVES DN15 - DN20 - DN25

Inspection Report	
TÜV AUSTRIA	

22-IS-0377

GAS BROKER S.R.L.

INSPECTION REPORT

Inspection Requested By	GAS BROKER S.R.L. Via Villa del Bosco, 18 35037 Teolo (PD) - Italy
Inspection Dates	11.05.2022
Report No:	22-IS-0377-TAT-22-0267
Report Date:	23.05.2022
Issued by:	TÜV AUSTRIA TURK Camlik Mah. Ikbal Cad. Dinc Sk. No:28/1 Umraniye / Istanbul

CONFORMITY TO

- ASCE 25-16 technical standard
- PED (essential requirements)

Inspection Report No: 22-IS-0377-TAT-22-0267

TÜV AUSTRIA

TÜV AUSTRIA

FRM-IND-002, Rev.01

...Conclusion

The third party audit was held on 11.05.2022 and it was determined that the products are in conformity with for ASCE 25-16 in the audit. The valves meet the basic safety requirements of 2014/68/EU.

PRODUCT CODE	WORKING POSITION	DIMENSION	CONNECTION TYPE	PRESSURE	PRODUCT NAME
SV-VT15C-05 (compact)	Vertical	1/2"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-HT15C-05 (compact)	Horizontal	1/2"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-VT15C-4 (compact)	Vertical	1/2"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-HT15C-4 (compact)	Horizontal	1/2"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-VT20C-05 (compact)	Vertical	3/4"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-HT20C-05 (compact)	Horizontal	3/4"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-VT20C-4 (compact)	Vertical	3/4"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-HT20C-4 (compact)	Horizontal	3/4"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-VT25C-05 (compact)	Vertical	1"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-HT25C-05 (compact)	Horizontal	1"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-VT25C-4 (compact)	Vertical	1"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-HT25C-4 (compact)	Horizontal	1"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-VT20-05	Vertical	3/4"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-HT20-05	Horizontal	3/4"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-VT20-4	Vertical	3/4"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-HT20-4	Horizontal	3/4"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-VT25-05	Vertical	1"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve
SV-HT25-05	Horizontal	1"	Threaded EN10226	500 mbar (7 PSIG)	Mechanical Earthquake Valve

Inspection Report No: 22-IS-0377-TAT-22-0267

TÜV AUSTRIA

FRM-IND-002, Rev.01

SV-VT25-4	Vertical	1"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve
SV-HT25-4	Horizontal	1"	Threaded EN10226	4 bar (60 PSIG)	Mechanical Earthquake Valve

6 Approvals & Disclaimers

The signatures below certify that this report has been reviewed and accepted and demonstrates that the signatories are aware of all the requirements contained herein and are committed to ensuring their provision.

This claim inspection report prepared on a best effort basis and is meant for information only. TÜV AUSTRIA TURK, with this report does not carry financial and legal obligation.

7 Photos

Attach photos as figures with the description;

SV-HT	SV-VT
	

	Name, Surname	Signature	Position	Date
Prepared by	Demet AKTÜRK		Technical Expert	23.05.2022
Approved by	Enes GÜNTAŞ		Industrial Inspector	23.05.2022